

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7170-1521:130

Page 1 of 1

CATEGORY: Control Units (High-Rise)

LISTEE: Siemens Building Technologies, Inc., 1000 Deerfield Parkway, Buffalo Grove, IL 60089
Contact: Fred Orpano (847) 941-6176 Fax (866) 699-0238

DESIGN: Model Insight Life Safety System fire alarm control unit. Proprietary and smoke control service. Refer to listee's data sheet for additional detailed product description and operational considerations. System Components:

Insight Database Server/Client
571-572 thru -579
571-587, -588, -589
PAL-1 P/N 571-583
571-580, -581

CPU
Work Stations
Monitors
Printer
Ethernet Switch

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control unit for use with Edwards Systems Technology Model EST3 Control Unit (CSFM 7165-1591:186 and 7170-1591:187) and Siemens Model ALS3 Control Unit (CSFM 7165-1521:114 and 7170-1521:118).

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

5-15-03 JEW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JULY 24, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager